



# PYROS FIRE SERVICES

Office: Plot No-2, Line NO-Q, Shop No-3, Main Road, Shivaji Nagar, Govandi, Mumbai-400 043.

Work Shop: Plot No-56, Janta Timber Market, G-M Link Road, Govandi, Mumbai-43

Contact: 8454910691/9594631281 Email Id: pyrosfireservices@gmail.com

REF:- PFS/25-26/281

DATE:- 04.07.2025

## Form B

[See Section 3(3) and rule 4(2)]

Six Monthly Certificates to be given in every JAN & JULY by the owner or the occupier for Compliance of Fire prevention and life safety measures.

## Certificate

Certified that I/We have carried out inspection of the fire prevention and life safety measures Installed in the following building or premises, namely:-

**M/S: -. "GOPI BIRLA MEMORIAL SCHOOL "**

**ADD: - WALKESHWAR ROAD, KRISHNARAJ SOCIETY, MALABAR HILL, MUMBAI 400006.**

I/we further certify that these installations in the above mentioned buildings are maintained in good repair and efficient conditions during the period six month (1<sup>st</sup> JAN 2025 to 30<sup>TH</sup> JUNE 2025), as required under the provision of Maharashtra Fire Prevention and Life safety Measures Act, 2006 (MAH III of 2007). The details of the inspection of the installations carried out by me/ we are mentioned in the report appended here with.

Place: Mumbai

Date: 04.07.2025

1. MFS/LA/RF-312
2. MFS/LA/RD-292

Signatories:

Signature valid

Digitally signed by FIROZ AHMED MOND, DN: cn=PYROS FIRE SERVICES/PERSONAL, Date: 2025.07.04 21:03:58, MAHARASHTRA, #00043, Designation: Authorized Signatory, Contact: 08454910691







# PYROS FIRE SERVICES

Office: Plot No-2, Line NO-Q, Shop No-3, Main Road, Shivaji Nagar, Govandi, Mumbai-400 043.

Work Shop: Plot No-56, Janta Timber Market, G-M Link Road, Govandi, Mumbai-43

Contact: 8454910691/9594631281

Email id: pyrosfireservices@gmail.com

REF:- PFS/25-26/281

DATE:- 04.07.2025

With reference cited above, below are the details of firefighting system at

**M/S:- "GOPI BIRLA MEMORIAL SCHOOL "**

**ADD:- WALKESHWAR ROAD, KRISHNARAJ SOCIETY, MALABAR HILL, MUMBAI 400006.**

## Annexure for Form B:

Sr no	Product description	Quantity	Unit	Remark
1	TERRACE BOOSTER PUMP 10 HP, SIZE 65 X 50	1	NOS	okay
2	GI, C CLASS PIPE SIZE - 80 MM, MAKE -JINDAL	24	METER	okay
3	BUTTER FLY VALVE 3"INCH(80MM)- CI	1	NOS	okay
4	WAFER TYPE NRV 3"INCH(80MM)- CI	1	NOS	okay
5	AIR RELEASE VALVE + BALL VALVE	1	NOS	okay
6	BALL VALVE 1"	1	NOS	okay
7	BALL VALVE 3/8 " + PRESSURE GUAGE	1	NOS	okay
8	HOSE REEL DRUM SET, ISI MARKED DRUM, MS -POWDER COATED, WITH TYPE 2, THERMOPLAST PVC HOSE REEL 19 MM DIA, PVC SHUT UP NOZZLE	7	NOS	okay
9	RRL CANVAS HOSE, WITH SS-ISI COUPLING, COPPER BINDING -15 MTRS LONG. (ALTERNATE FLOORS + YARD)	7	NOS	okay
10	MS DOUBLE DOOR HOSE BOX -POWDER COATED-HEAVY	7	NOS	okay
11	CONTROL PANEL FOR BOOSTER PUMPS, HAVING AUTO & MANUAL MODE	1	NOS	okay
12	MCB FOR BOOSTER PUMPS	1	NOS	okay
13	REMOTE SWITCH FOR BOOSTER PUMPS	1	NOS	okay
14	3 CORE 2.5 MM SQUARE, ARMoured CABLE FOR BOOSTER PUMP	45	NOS	okay
15	DANFOSS PRESSURE SWITCH FOR BOOSTER PUMP	1	NOS	okay
16	FABRICATING 02 WAT FIRE MAN INLET	1	NOS	okay
17	PRESSURE SWITCH FOR AUTOMATION.	1	NOS	okay
18	PRESSURE VESSEL FOR FIRE HYDRANT SYSTEM	1	NOS	okay
	<b>FIRE SPRINKLER SYSTEM. (MAIN TAPPING FROM, NEW BUILDING)</b>			
19	PENDANT SPRINKLER HEAD. 68 DEG	87	NOS	okay
20	SIDE WALL SPRINKLER HEAD. 68 DEG	89	NOS	okay
21	BUTTERFLY VALVE 65 MM DIA, WITH PAIRING FLANGES GASKETS & NUT BOLTS	5	NOS	okay
22	BUTTERFLY VALVE 50 MM DIA, WITH PAIRING FLANGES GASKETS & NUT BOLTS	2	NOS	okay
23	SS FLEXIBLE HOSE, UL / FM APPROVED with required rosette plate.	87	NOS	okay
24	GI, C CLASS PIPE SIZE - 150 MM, MAKE -JINDAL	70	NOS	okay
25	100 DIA, PRESSURE GUAGE 14 KG RATED.	7	NOS	okay
26	BALL VALVE 25 MM DIA, WITH UNION & PIPES	7	NOS	okay
27	BUTTERFLY VALVE 150 MM DIA, WITH PAIRING FLANGES.	1	NOS	okay
	<b>FIRE ALARM SYSTEM</b>			
28	SMOKE DETECTOR FOR THE PASSAGE OF FLOORS	35	NOS	okay
29	MCP CUM HOOTER	11	NOS	okay





30	CONVENTIONAL FIRE ALARM PANEL	1	NOS	Okay
	<b>AUTO GLOW SIGNAGES</b>			
31	AUTO GLOW SIGNAGES - ON 03 MM PVC SHEET , STANDARD SITE FOR FLOOR NUMBER , EXIT, METER ROOMS ETC	28	NOS	okay

The above said fire Protection equipment installed in good working condition.

There after any alteration in above system by occupant or developer will make this certificate invalid.

Thanking You.

License Number:

1. MFS/LA/RF-312

2. MFS/LA/RD-292

Signatories:

Signature valid

Digitally signed by FROZ AHMED MOHD IS  
PYROS FIRE SERVICES PERSONAL  
Date: 2020.07.04 21:04:30  
MAHARASHTRA  
400043  
Designation: Authorized  
Contact: 08454910891





for reference only, not for official use.



Govt. of Maharashtra  
Directorate of Maharashtra Fire Service  
Vidyanagri, Hans Bhugra Marg, Santacruz (East).  
Mumbai - 400 098. Tel-022-26677555, Fax-022-26677666  
www.mahafireservice.gov.in

**FORM N**  
**[ ( See section 9 (3) and rule 14 )**  
**License to act as a License Agency for the purpose of**  
**Fire Prevention and Life Safety Measure**

License No. MFS / LA / RF-312 / RD- 292

Date: 31.05.2024

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Pyros Fire Services** having their registered office at **Plot No. 02/L/6, Shivaji Nagar, Govandi 400043** and their contact details are Office Number: 8454910691 and Email ID: pyrosfireservices@gmail.com with PAN registration No. BVDPK2919K and GST No. 27BVDPK2919K1ZD to act as a Licensed Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

*Gopi Bida memorial school.*

1. Fire Fighting and Sprinkler System: Class D
2. Detection and Fire Suppression System: Class D

FOR SITE: -

**M/s. Pyros Fire Services** shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

for reference only, not for official use.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **31.05.2024 to 30.05.2026**

Hatyal  
Kiran  
Asst Director

Digitally signed by  
Kiran  
Date: 2024.06.11  
11:22:05 +05'30'

Digitally signed by FROZ AHMED  
MOHD ISAK KHAN  
Date: 2024.06.05.20.08.48

Santosh  
Warick  
( S S Warick )  
Director  
Maharashtra Fire Service

Digitally signed by  
Santosh Warick  
Date: 2024.06.11  
22:11:21 +05'30'

Digital Signature of Authorized Person to sign Form A or Form B

Note:

for reference only, not for official use.

\* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.

FOR SITE: -

*Gopi Bida memorial school.*

